



## Sustained Transmission Disruption Report

*Released Report Date & Time*

10/20/2015

14:33

<b>District</b>	Northern
<b>Cause</b>	Beaver dropped tree on Line
<b>Sub</b>	Easton, Westfield, Oakfield, Island Falls, Patten, Sherman, Mars Hill, Bridgewater, Monticello, Houlton Water Company
<b>Line</b>	6950
<b>Pole #</b>	N/A
<b>Phase</b>	Three
<b>Date Out</b>	10/20/2015
<b>Time Out</b>	4:13
<b>Time In</b>	Easton 04:51, Westfield 05:14, Oakfield 04:27, Island Falls 04:27, Patten 04:27, Sherman 04:27, Mars Hill - Momentary, Bridgewater - Momentary, Monticello - Momentary, Houlton Water Company - Momentary
<b>Duration</b>	Easton 0:38, Westfield 0:61, Oakfield 0:14, Island Falls 0:14, Patten 0:14, Sherman 0:14, Mars Hill - Momentary, Bridgewater - Momentary, Monticello - Momentary, Houlton Water Company - Momentary
<b>Customers Affected</b>	Easton 950, Westfield 391, Oakfield 639, Island Falls 976, Patten 408, Sherman 890, Mars Hill - Momentary, Bridgewater - Momentary, Monticello - Momentary, Houlton Water Company - Momentary